

Oregon Trail School District

Water testing status: December 2016

FACILITY	DRINKING FOUNTAINS # of locations tested	>20 PPB EPA ACTION LEVEL	FOOD PREP SINKS # of locations tested	>20 PPB EPA ACTION LEVEL	FAUCETS / SINKS # of locations tested	>20 PPB EPA ACTION LEVEL	RESOLUTION *see key below
Elementary schools							
Firwood	30	0	2	0	32	10	1
Kelso	16	1	4	2	15	1	1
Naas	20	0	7	0	18	0	1
Sandy Grade	10	4	5	2	23	6	1
Welches	13	0	N/A	N/A	18	11	1
Middle schools							
Boring	15	0	N/A	N/A	17	5	1
Cedar Ridge	15	12	N/A	N/A	31	20	2
Welches	14	7	2	2	24	23	3
High school							
Sandy	41	0	10	4	40	11	1
Charter school							
Oregon Trail Academy	13	0	3	0	16	0	N/A
District							
Community Connections			1	1	N/A	N/A	1
Blended Learning Center	2	0	N/A	N/A	N/A	N/A	1
Pioneer Building							4

- 1: Resolved: fixtures replaced or shut-down.
- 2: Cedar Ridge Middle School: fixtures >20 PPB shut-down; water coolers being used for remainder of school year.
- 3: Welches Middle School: fixtures > 20 PPB shut-down; water coolers being used; neutralizing system being installed.
- 4: Pioneer Building: testing in process; facility being renovated.